



# WASHINGTON COUNTY HEALTH DEPARTMENT

1302 Pennsylvania Avenue • Hagerstown, MD 21742

[www.washhealth.org](http://www.washhealth.org)

#PUR-2017-04

Chiller Replacement

ADDENDUM #1

Date: January 22, 2018

BIDS DUE: Wednesday, January 31, 2018  
No later than 10:00 A.M.

To Bidders:

This Addendum is hereby made a part of the contract documents on which all bids will be based and is issued to correct and clarify the original documents.

Please acknowledge receipt of this Addendum at the appropriate space on the Proposal Form. This Addendum consists of one (1) page.

ITEM NO. #1: Drawing M101 dated 12/1/17, "General Notes"

Add the following:

- A. General Piping
  - 1. Provide Pre-Demo Water Flow Test
  - 2. Provide Flow Meters and balance valves on two (2) – 4 inch CWR pipes in mechanical room

BY AUTHORITY OF:

Dan Triplett  
Administrator

ADMINISTRATION DIVISION

240-313-3255 • 240-313-3391 TDD • 240-313-3301 Fax